






Mercer Island Fire Marshal's Office  
 3030 78<sup>th</sup> Avenue SE  
 Mercer Island, WA 98040  
 (206) 275-7966

# Mercer Island Fire Standpipe Design



"CAP TYPE DOUBLE CLAPPERED DOUBLE FEMALE NST SIAMESE WITH CHAINS AND PLUGS."

### FDC SIGN



**NOTE:**

**SIGN REQUIREMENTS**

1. ALL MATERIALS SHALL BE NFPA 14 COMPLIANT.
2. SIGN AND LETTER COLORS  
SIGN SHALL BE WHITE LETTERS ON A RED BACKGROUND.
3. SIZE AND MATERIAL  
2" BLOCK LETTERS STENCIL PAINTED ON METAL OR
4. SIGN TERMINOLOGY
  - A. SPRINKLERS ONLY: "SPRINKLER" WITH JOB ADDRESS.
  - B. SPRINKLERS AND INTERIOR STANDPIPE: "SPRINKLER-STANDPIPE" WITH JOB ADDRESS.
  - C. STANDPIPE ONLY: "STANDPIPE" WITH JOB ADDRESS.
5. ADDRESS NUMERALS SHALL BE ABOVE SYSTEM TYPE.
6. NEED TO SHOW HOW TO/WHERE TO INSTALL BALL DRIP.



\* Permit Required

Mercer Island CPD  
 9611 SE 36th Street  
 Mercer Island, WA 98040

206-275-7605