United States
Environmental Protection
Agency

The Fourth Unregulated Contaminant Monitoring Rule (UCMR 4)

General Information

What is the Unregulated Contaminant Monitoring Rule?

The 1996 amendments to the Safe Drinking Water Act (SDWA) require that once every five years, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWSs). The Unregulated Contaminant Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. This national survey is one of the primary sources of information on occurrence and levels of exposure that the Agency uses to develop regulatory decisions for contaminants in the public drinking water supply.

The "Revisions to the Unregulated Contaminant Monitoring Rule (UCMR 4) for Public Water Systems and Announcement of Public Meeting" was published in the *Federal Register* on December 20, 2016 (81 FR 92666). UCMR 4 monitoring will occur from 2018-2020 and includes monitoring for a total of 30 chemical contaminants: 10 cyanotoxins (nine cyanotoxins and one cyanotoxin group) and 20 additional contaminants (two metals, eight pesticides plus one pesticide manufacturing byproduct, three brominated haloacetic acid [HAA] disinfection byproducts groups, three alcohols, and three semivolatile organic chemicals [SVOCs]).

What contaminants are systems monitoring for under UCMR 4?

Under UCMR 4, PWSs will conduct sampling for Assessment Monitoring ("List 1") contaminants as shown in the table below. For additional information on these contaminants, please review the contaminant-specific UCMR 4 Fact Sheets.

10 Cyanotoxins (Nine Cyanotoxins and One Cyanotoxin Group)

total microcystins	microcystin-LA	microcystin-RR	microcystin-LF	microcystin-YR
microcystin-LR	microcystin-LY	nodularin	cylindrospermopsin	anatoxin-a

20 Additional Contaminants

germanium	manganese	alpha-hexachlorocyclohexane	profenofos	chlorpyrifos
tebuconazole	dimethipin	total permethrin (cis- & trans-)	ethoprop	tribufos
oxyfluorfen	HAA5[1]	HAA6Br[1]	HAA9[1]	1-butanol
2-propen-1-ol	2-methoxyethanol	butylated hydroxyanisole	o-toluidine	quinoline

1. HAA5 (dibromoacetic acid, dichloroacetic acid, monobromoacetic acid, monochloroacetic acid, trichloroacetic acid); HAA6Br (bromochloroacetic acid, bromodichloroacetic acid, dibromoacetic acid, chlorodibromoacetic acid, monobromoacetic acid, tribromoacetic acid); HAA9 (bromochloroacetic acid, bromodichloroacetic acid, chlorodibromoacetic acid, dibromoacetic acid, dichloroacetic acid, monobromoacetic acid, monochloroacetic acid, tribromoacetic acid, and trichloroacetic acid).

Which water systems will participate in UCMR 4?

Approximately 6,000 PWSs will participate in UCMR 4. All community water systems (CWSs) and non-transient non-community water systems (NTNCWSs) serving more than 10,000 people (i.e., large systems) are required to monitor:

- All large surface water (SW) and ground water under the direct influence of surface water (GWUDI) systems will monitor for cyanotoxins and the 20 additional contaminants.
- All large ground water systems will monitor for the 20 additional contaminants.

Of the CWSs and NTNCWSs serving 10,000 or fewer people (i.e., small systems):

- A nationally representative set of 800 randomly selected SW and GWUDI small systems will monitor for cyanotoxins.
- A different set of 800 randomly selected small systems will monitor for the 20 additional contaminants.

Note that any PWS that is not subject to HAA5 monitoring under the D/DBPRs (40 CFR 141.Subparts L and V) is not required to monitor for the UCMR 4 HAAs or associated indicators (total organic carbon (TOC) and bromide). Also, transient non-community water systems (TNCWSs) are not required to monitor under UCMR 4.

Where will samples be collected?

UCMR 4 samples will be collected at entry points to the distribution system (EPTDS) for all contaminant groups except for the HAAs, which will be taken in the distribution system. Sampling for the HAA indicators (TOC and bromide) will take place at a single source water influent for each treatment plant.

What does UCMR 4 participation involve?

All large systems and only small systems notified by their state or EPA, will collect samples and have them analyzed for UCMR 4 contaminants. As with previous UCMRs, large PWSs pay for their own testing. EPA pays for the analytical costs for the selected small systems.

All laboratories conducting analyses for UCMR 4 contaminants must receive EPA UCMR approval to perform those analyses.

How did EPA select the UCMR 4 contaminants?

The Contaminant Candidate List (CCL) was the primary source of priority contaminants considered for UCMR 4. The CCL is a list of contaminants that are not currently addressed by national primary drinking water regulations, are known or anticipated to occur at public water systems and may warrant regulation. The EPA selected the UCMR 4 contaminants using a stepwise prioritization process. The first step identified contaminants that were not monitored under UCMR 2 or UCMR 3; may have significant occurrence nationally; and have a completed, validated drinking water method. The next step focused on contaminants associated with one or more of the following considerations: an available health assessment to facilitate regulatory determinations; high public concern; critical health endpoints (e.g., likely or suggestive carcinogen); active use (e.g., pesticides); and/or an occurrence data gap. During the final step, EPA considered workgroup and stakeholder input; looked at cost-effectiveness of analytical methods (i.e., can a single method address multiple contaminants of interest); considered implementation factors (e.g., laboratory capacity); and further evaluated health, occurrence and persistence/mobility data to identify the list of 30 UCMR 4 contaminants.

What are the public health benefits of the UCMR program?

The UCMR program provides the EPA and other interested parties with nationally representative data on the occurrence of particular contaminants in drinking water, the number of people potentially being exposed and an estimate of the levels of that exposure. In accordance with SDWA, EPA will consider the occurrence data from UCMR 4 and other sources, along with the peer reviewed health effects assessments, to support a regulatory determination on whether to initiate the process to develop a national primary drinking water regulation.

Where can consumers find UCMR results?

CWSs are required to address their UCMR monitoring results in their annual Consumer Confidence Report (CCR) whenever unregulated contaminants are detected. CCRs are delivered to all billing customers each year by July 1. (The CCR Rule does not apply to non-community water systems). To obtain a copy of your CCR, you should contact your water supplier or you may find information for how to obtain a copy of the CCR in your water bill. Additional information about the CCR including details on reporting requirements can be found on the CCR Homepage.

All PWSs are required to report their data to EPA as outlined in the UCMR. The analytical results from UCMR 4 (and previous UCMRs) are stored in the National Contaminant Occurrence Database (NCOD) for drinking water. For a summary of the NCOD results, tips for querying NCOD and health effects information (including reference concentrations), please refer to the UCMR 4 Data Summary document.

How can I learn more?

General information is available on the UCMR web page or by calling the Safe Drinking Water Hotline at 1-800-426-4791.

CLIENT	PROJECT	PROJECTNUM	LabName	SAMPLENAME	LABSAMPID	MATRIX	RPTMATRIX	SAMPDATE	PREPDATE	ANADATE	BATCH	METHODCODE	METHODNAME	PREPNAME	ANALYTE	CASNUMBER	SURROGATE	TIC	Result	DL	RL	UNITS	RPToMDL	BASIS	DILUTION	SPIKELEVEL	RECOVERY	UPPERCL	LOWERCL	ANALYST	PSOLIDS	LNOTE	ANOTE	LATITUDE	LONGITUDE	sComment	SNOTE1	SNOTE2	SNOTE3	SNOTE4	SNOTE5	SNOTE6	SNOTE7	SNOTE8	SNOTE9	SNOTE10	ANALYTEORDER
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 12:00:00	05/21/2018 14:45:56	A806671	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Germanium	7440-56-4	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PSK							19890	WA5353640	EP001	SEA1	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 12:00:00	05/21/2018 14:45:56	A806671	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Manganese	7439-96-5	FALSE	FALSE	1.7	0.13	0.40	ug/L	FALSE	NA	1					PSK							19890	WA5353640	EP001	SEA1	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 12:00:00	05/21/2018 14:45:56	A806671	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Yttrium	7440-65-5	FALSE	FALSE	0.0			ug/L	FALSE	NA	1	20000		125	60	PSK							19890	WA5353640	EP001	SEA1	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Alpha-Hexachlorocyclohexane	319-84-6	FALSE	FALSE	ND	0.0033	0.010	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Chlorpyrifos	2921-88-2	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Dimethipin		FALSE	FALSE	ND	0.067	0.20	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			3
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Ethoprop	13194-48-4	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			4
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Oxyfluorfen		FALSE	FALSE	ND	0.017	0.050	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			5
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Profenophos		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			6
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Tebuconazole	107534-96-3	FALSE	FALSE	ND	0.067	0.20	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			7
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Total Permethrin (cis & trans)	52645-53-1	FALSE	FALSE	ND	0.013	0.040	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			10
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Tribufos (DEF)	78-48-8	FALSE	FALSE	ND	0.023	0.070	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			11
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	1,3-Dimethyl-2-nitrobenzene		TRUE	FALSE	0.94			ug/L	FALSE	NA	1	0.953	99	130	70	JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			800
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Triphenyl Phosphate	115-86-6	TRUE	FALSE	1.1			ug/L	FALSE	NA	1	0.953	119	130	70	JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			801
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Benzo(a)pyrene-d12	63466-71-7	TRUE	FALSE	0.95			ug/L	FALSE	NA	1	0.953	100	130	70	JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			802
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Acenaphthene-d10		FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Phenanthrene-d10	NA	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/14/2018 10:06:00	05/15/2018 19:28:00	A806658	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Chrysene-d12	1719-03-5	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							19890	WA5353640	EP001	SEA1	EP		CC	SW			902
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/16/2018 06:23:00	05/17/2018 19:53:00	A806817	UCMR4, EPA 530	EPA 530	EPA 530	Butylated hydroxyanisole (BHA)	25013-16-5	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA1	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/16/2018 06:23:00	05/17/2018 19:53:00	A806817	UCMR4, EPA 530	EPA 530	EPA 530	o-Toluidine	95-53-4	FALSE	FALSE	0.0091	0.0023	0.0070	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA1	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/16/2018 06:23:00	05/17/2018 19:53:00	A806817	UCMR4, EPA 530	EPA 530	EPA 530	Quinoline		FALSE	FALSE	ND	0.0067	0.020	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA1	EP		CC	SW			3
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/16/2018 06:23:00	05/17/2018 19:53:00	A806817	UCMR4, EPA 530	EPA 530	EPA 530	o-Toluidine-d9	194423-47-7	TRUE	FALSE	4.9			ug/L	FALSE	NA	1	4.78	102	130	50	PNN							19890	WA5353640	EP001	SEA1	EP		CC	SW			800
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/16/2018 06:23:00	05/17/2018 19:53:00	A806817	UCMR4, EPA 530	EPA 530	EPA 530	Quinoline-d7	34071-94-8	TRUE	FALSE	5.0			ug/L	FALSE	NA	1	4.78	105	130	70	PNN							19890	WA5353640	EP001	SEA1	EP		CC	SW			801
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/16/2018 06:23:00	05/17/2018 19:53:00	A806817	UCMR4, EPA 530	EPA 530	EPA 530	Acenaphthene-d10		FALSE	FALSE	1000			ng/mL	FALSE	NA	1	25000	4	130	70	PNN							19890	WA5353640	EP001	SEA1	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/16/2018 06:23:00	05/17/2018 19:53:00	A806817	UCMR4, EPA 530	EPA 530	EPA 530	Phenanthrene-d10	NA	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	25000	4	130	70	PNN							19890	WA5353640	EP001	SEA1	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/15/2018 09:38:00	05/17/2018 13:11:00	A806738	UCMR4, EPA 541	EPA 541	EPA 541	Allyl alcohol	107-18-6	FALSE	FALSE	ND	0.17	0.50	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEA1	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/15/2018 09:38:00	05/17/2018 13:11:00	A806738	UCMR4, EPA 541	EPA 541	EPA 541	n-Butyl alcohol	71-36-3	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEA1	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/15/2018 09:38:00	05/17/2018 13:11:00	A806738	UCMR4, EPA 541	EPA 541	EPA 541	2-Methoxyethanol	109-86-4	FALSE	FALSE	ND	0.13	0.40	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEA1	EP		CC	SW			3
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/15/2018 09:38:00	05/17/2018 13:11:00	A806738	UCMR4, EPA 541	EPA 541	EPA 541	n-Butyl alcohol-d10	34193-38-9	TRUE	FALSE	9.2			ug/L	FALSE	NA	1	10.0	92	130	70	JMM							19890	WA5353640	EP001	SEA1	EP		CC	SW			801
City of Mercer Island, WA	UCMR4	[none]	BSK Associates Laboratory Fresno	Seattle Intertie	V8D0476-01	Water	Water	05/09/2018 09:04:00	05/15/2018 09:38:00	05/17/2018 13:11:00	A806738	UCMR4, EPA 541	EPA 541	EPA 541	Chlorobenzene-d5	03114-55-4	FALSE	FALSE	250			ng/mL	FALSE	NA	1	25000	1	130	70	JMM							19890	WA5353640	EP001	SEA1	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/12/2018 00:22:00	05/12/2018 00:22:30	A806584	UCMR4 Bromide, Low Level	EPA 300.1	Method Specific Preparation	Bromide	24959-67-9	FALSE	FALSE	ND	6.7	20	ug/L	FALSE	NA	1					RES							00001	WA5353640	SSEAST	SEH1	DS						3
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/12/2018 00:22:00	05/12/2018 00:22:30	A806584	UCMR4 Bromide, Low Level	EPA 300.1	Method Specific Preparation	Dichloroacetate		TRUE	FALSE	530			ug/L	FALSE	NA	1	500	105	115	90	RES							00001	WA5353640	SSEAST	SEH1	DS						800
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.37	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	1.0	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						2
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						3
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						4
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						5
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						6
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	7.3	0.067	0.20	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						7
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						8
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/16/2018 12:08:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	28	0.85	2.5	ug/L	FALSE	NA	5					JKH							00001	WA5353640	SSEAST	SEH1	DS						9
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	10			ug/L	FALSE	NA	1	10.0	101	130	70	JKH							00001	WA5353640	SSEAST	SEH1	DS						800
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:10:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	JKH							00001	WA5353640	SSEAST	SEH1	DS						900
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSEast	V8D0477-01	Water	Water	05/03/2018 00:00:00	05/16/2018 04:18:00	05/16/2018 04:18:00	A806789	UCMR4 TOC, Total Organic Carbon	SM 5310C	Method Specific Preparation	Total Organic Carbon		FALSE	FALSE	ND	330	1000	ug/L	FALSE	NA	1					CEG							00001	WA5353640	SSEAST	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/12/2018 00:52:00	05/12/2018 00:52:32	A806584	UCMR4 Bromide, Low Level	EPA 300.1	Method Specific Preparation	Bromide	24959-67-9	FALSE	FALSE	ND	6.7	20	ug/L	FALSE	NA	1					RES							00001	WA5353640	SSNORTH	SEH1	DS						3
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/12/2018 00:52:00	05/12/2018 00:52:32	A806584	UCMR4 Bromide, Low Level	EPA 300.1	Method Specific Preparation	Dichloroacetate		TRUE	FALSE	550			ug/L	FALSE	NA	1	500	109	115	90	RES							00001	WA5353640	SSNORTH	SEH1	DS						800
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.55	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	1.1	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						2
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						3
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						4
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						5
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						6
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/16/2018 12:33:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	13	0.34	1.0	ug/L	FALSE	NA	5					JKH							00001	WA5353640	SSNORTH	SEH1	DS						7
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						8
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/16/2018 12:33:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	27	0.85	2.5	ug/L	FALSE	NA	5					JKH							00001	WA5353640	SSNORTH	SEH1	DS						9
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	10			ug/L	FALSE	NA	1	10.0	104	130	70	JKH							00001	WA5353640	SSNORTH	SEH1	DS						800
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 21:36:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	JKH							00001	WA5353640	SSNORTH	SEH1	DS						900
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSNorth	V8D0477-02	Water	Water	05/03/2018 00:00:00	05/16/2018 03:11:00	05/16/2018 03:11:00	A806789	UCMR4 TOC, Total Organic Carbon	SM 5310C	Method Specific Preparation	Total Organic Carbon		FALSE	FALSE	ND	330	1000	ug/L	FALSE	NA	1					CEG							00001	WA5353640	SSNORTH	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/12/2018 01:22:00	05/12/2018 01:22:34	A806584	UCMR4 Bromide, Low Level	EPA 300.1	Method Specific Preparation	Bromide	24959-67-9	FALSE	FALSE	ND	6.7	20	ug/L	FALSE	NA	1					RES							00001	WA5353640	SSSOUTH	SEH1	DS						3
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/12/2018 01:22:00	05/12/2018 01:22:34	A806584	UCMR4 Bromide, Low Level	EPA 300.1	Method Specific Preparation	Dichloroacetate		TRUE	FALSE	500			ug/L	FALSE	NA	1	500	100	115	90	RES							00001	WA5353640	SSSOUTH	SEH1	DS						800
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	1.0	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						2
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						3
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						4
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						5
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						6
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	2.5	0.067	0.20	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						7
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						8
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/16/2018 12:59:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	26	0.85	2.5	ug/L	FALSE	NA	5					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						9
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	10			ug/L	FALSE	NA	1	10.0	103	130	70	JKH							00001	WA5353640	SSSOUTH	SEH1	DS						800
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:02:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	JKH							00001	WA5353640	SSSOUTH	SEH1	DS						900
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSSouth	V8D0477-03	Water	Water	05/03/2018 00:00:00	05/16/2018 04:31:00	05/16/2018 04:31:00	A806789	UCMR4 TOC, Total Organic Carbon	SM 5310C	Method Specific Preparation	Total Organic Carbon		FALSE	FALSE	ND	330	1000	ug/L	FALSE	NA	1					CEG							00001	WA5353640	SSSOUTH	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/12/2018 01:52:00	05/12/2018 01:52:36	A806584	UCMR4 Bromide, Low Level	EPA 300.1	Method Specific Preparation	Bromide	24959-67-9	FALSE	FALSE	ND	6.7	20	ug/L	FALSE	NA	1					RES							00001	WA5353640	SSWEST	SEH1	DS						3
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/12/2018 01:52:00	05/12/2018 01:52:36	A806584	UCMR4 Bromide, Low Level	EPA 300.1	Method Specific Preparation	Dichloroacetate		TRUE	FALSE	550			ug/L	FALSE	NA	1	500	110	115	90	RES							00001	WA5353640	SSWEST	SEH1	DS						800
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.49	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	1.0	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						2
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						3
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						4
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						5
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						6
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/16/2018 13:24:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	12	0.34	1.0	ug/L	FALSE	NA	5					JKH							00001	WA5353640	SSWEST	SEH1	DS						7
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						8
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/16/2018 13:24:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	27	0.85	2.5	ug/L	FALSE	NA	5					JKH							00001	WA5353640	SSWEST	SEH1	DS						9
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	10			ug/L	FALSE	NA	1	10.0	103	130	70	JKH							00001	WA5353640	SSWEST	SEH1	DS						800
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/14/2018 08:15:00	05/15/2018 22:53:00	A806652	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	JKH							00001	WA5353640	SSWEST	SEH1	DS						900
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	SSWest	V8D0477-04	Water	Water	05/03/2018 00:00:00	05/16/2018 04:44:00	05/16/2018 04:44:00	A806789	UCMR4 TOC, Total Organic Carbon	SM 5310C	Method Specific Preparation	Total Organic Carbon		FALSE	FALSE	ND	330	1000	ug/L	FALSE	NA	1					CEG							00001	WA5353640	SSWEST	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8D0478-01	Water	Water	05/08/2018 09:34:00	05/11/2018 12:41:00	05/16/2018 12:57:24	A806593	UCMR4, EPA 545	EPA 545	EPA 545	Anatoxin-a	64285-06-9	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC1	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8D0478-01	Water	Water	05/08/2018 09:34:00	05/11/2018 12:41:00	05/16/2018 12:57:24	A806593	UCMR4, EPA 545	EPA 545	EPA 545	Cylindrospermopsin	143545-90-8	FALSE	FALSE	ND	0.030	0.090	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC1	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8D0478-01	Water	Water	05/08/2018 09:34:00	05/11/2018 12:41:00	05/16/2018 12:57:24	A806593	UCMR4, EPA 545	EPA 545	EPA 545	Uracil-d4	24897-55-0	FALSE	FALSE	20			ug/L	FALSE	NA	1	1000	2	150	50	JMM							19890	WA5353640	EP001	SEC1	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8D0478-01	Water	Water	05/08/2018 09:34:00	05/11/2018 12:41:00	05/16/2018 12:57:24	A806593	UCMR4, EPA 545	EPA 545	EPA 545	L-Phenylalanine-d5	56253-90-8	FALSE	FALSE	5.0			ug/L	FALSE	NA	1	250	2	150	50	JMM							19890	WA5353640	EP001	SEC1	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8D0478-01	Water	Water	05/08/2018 09:34:00	05/18/2018 13:34:00	05/18/2018 13:34:00	A806504	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	Total Microcystin	NA	FALSE	FALSE	ND	0.15	0.30	ug/L	FALSE	NA	1					KTN							19890	WA5353640	EP001	SEC1	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	SE1	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8D0478-01	Water	Water	05/08/2018 09:34:00	05/18/2018 13:34:00	05/18/2018 13:34:00	A806504	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	%CV (abs.)		TRUE	FALSE	2.1			ug/L	FALSE	NA	1	1000	0.2	15	0	KTN							19890	WA5353640	EP001	SEC1	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	May Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0262-01	Water	Water	05/22/2018 08:23:00	05/30/2018 14:18:00	06/01/2018 18:53:22	A807583	UCMR4, EPA 545	EPA 545	EPA 545	Anatoxin-a	64285-06-9	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC2	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	May Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0262-01	Water	Water	05/22/2018 08:23:00	05/30/2018 14:18:00	06/01/2018 18:53:22	A807583	UCMR4, EPA 545	EPA 545	EPA 545	Cylindrospermopsin	143545-90-8	FALSE	FALSE	ND	0.030	0.090	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC2	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	May Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0262-01	Water	Water	05/22/2018 08:23:00	05/30/2018 14:18:00	06/01/2018 18:53:22	A807583	UCMR4, EPA 545	EPA 545	EPA 545	Uracil-d4	24897-55-0	FALSE	FALSE	20			ug/L	FALSE	NA	1	1000	2	150	50	JMM							19890	WA5353640	EP001	SEC2	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	May Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0262-01	Water	Water	05/22/2018 08:23:00	05/30/2018 14:18:00	06/01/2018 18:53:22	A807583	UCMR4, EPA 545	EPA 545	EPA 545	L-Phenylalanine-d5	56253-90-8	FALSE	FALSE	5.0			ug/L	FALSE	NA	1	250	2	150	50	JMM							19890	WA5353640	EP001	SEC2	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	May Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0262-01	Water	Water	05/22/2018 08:23:00	06/04/2018 15:23:00	06/04/2018 15:23:00	A807336	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	Total Microcystin	NA	FALSE	FALSE	ND	0.15	0.30	ug/L	FALSE	NA	1					KTN							19890	WA5353640	EP001	SEC2	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	May Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0262-01	Water	Water	05/22/2018 08:23:00	06/04/2018 15:23:00	06/04/2018 15:23:00	A807336	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	%CV (abs.)		TRUE	FALSE	0.70			ug/L	FALSE	NA	1	1000	0.07	15	0	KTN							19890	WA5353640	EP001	SEC2	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3 June Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0263-01	Water	Water	06/05/2018 07:40:00	06/07/2018 14:39:00	06/08/2018 13:49:41	A808032	UCMR4, EPA 545	EPA 545	EPA 545	Anatoxin-a	64285-06-9	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC3	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3 June Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0263-01	Water	Water	06/05/2018 07:40:00	06/07/2018 14:39:00	06/08/2018 13:49:41	A808032	UCMR4, EPA 545	EPA 545	EPA 545	Cylindrospermopsin	143545-90-8	FALSE	FALSE	ND	0.030	0.090	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC3	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3 June Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0263-01	Water	Water	06/05/2018 07:40:00	06/07/2018 14:39:00	06/08/2018 13:49:41	A808032	UCMR4, EPA 545	EPA 545	EPA 545	Uracil-d4	24897-55-0	FALSE	FALSE	20			ug/L	FALSE	NA	1	1000	2	150	50	JMM							19890	WA5353640	EP001	SEC3	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	AM3 June Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0263-01	Water	Water	06/05/2018 07:40:00	06/07/2018 14:39:00	06/08/2018 13:49:41	A808032	UCMR4, EPA 545	EPA 545	EPA 545	L-Phenylalanine-d5	56253-90-8	FALSE	FALSE	5.0			ug/L	FALSE	NA	1	250	2	150	50	JMM							19890	WA5353640	EP001	SEC3	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM3 June Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0263-01	Water	Water	06/05/2018 07:40:00	06/14/2018 15:04:00	06/14/2018 15:04:00	A807950	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	Total Microcystin	NA	FALSE	FALSE	ND	0.15	0.30	ug/L	FALSE	NA	1					KTN							19890	WA5353640	EP001	SEC3	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3 June Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0263-01	Water	Water	06/05/2018 07:40:00	06/14/2018 15:04:00	06/14/2018 15:04:00	A807950	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	%CV (abs.)		TRUE	FALSE	2.0			ug/L	FALSE	NA	1	1000	0.2	15	0	KTN							19890	WA5353640	EP001	SEC3	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3 June Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0264-01	Water	Water	06/19/2018 09:29:00	06/21/2018 09:01:00	06/21/2018 14:49:12	A808800	UCMR4, EPA 545	EPA 545	EPA 545	Anatoxin-a	64285-06-9	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC4	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3 June Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0264-01	Water	Water	06/19/2018 09:29:00	06/21/2018 09:01:00	06/21/2018 14:49:12	A808800	UCMR4, EPA 545	EPA 545	EPA 545	Cylindrospermopsin	143545-90-8	FALSE	FALSE	ND	0.030	0.090	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC4	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3 June Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0264-01	Water	Water	06/19/2018 09:29:00	06/21/2018 09:01:00	06/21/2018 14:49:12	A808800	UCMR4, EPA 545	EPA 545	EPA 545	Uracil-d4	24897-55-0	FALSE	FALSE	20			ug/L	FALSE	NA	1	1000	2	150	50	JMM							19890	WA5353640	EP001	SEC4	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	AM3 June Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0264-01	Water	Water	06/19/2018 09:29:00	06/21/2018 09:01:00	06/21/2018 14:49:12	A808800	UCMR4, EPA 545	EPA 545	EPA 545	L-Phenylalanine-d5	56253-90-8	FALSE	FALSE	5.0			ug/L	FALSE	NA	1	250	2	150	50	JMM							19890	WA5353640	EP001	SEC4	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM3 June Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0264-01	Water	Water	06/19/2018 09:29:00	06/28/2018 14:22:00	06/28/2018 14:22:00	A808759	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	Total Microcystin	NA	FALSE	FALSE	ND	0.15	0.30	ug/L	FALSE	NA	1					KTN							19890	WA5353640	EP001	SEC4	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3 June Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8E0264-01	Water	Water	06/19/2018 09:29:00	06/28/2018 14:22:00	06/28/2018 14:22:00	A808759	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	%CV (abs.)		TRUE	FALSE	2.1			ug/L	FALSE	NA	1	1000	0.2	15	0	KTN							19890	WA5353640	EP001	SEC4	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3 July Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0342-01	Water	Water	07/05/2018 08:38:00	07/09/2018 08:12:00	07/09/2018 14:54:48	A809673	UCMR4, EPA 545	EPA 545	EPA 545	Anatoxin-a	64285-06-9	FALSE	FALSE	ND	0.0030	0.030	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC5	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3 July Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0342-01	Water	Water	07/05/2018 08:38:00	07/09/2018 08:12:00	07/09/2018 14:54:48	A809673	UCMR4, EPA 545	EPA 545	EPA 545	Cylindrospermopsin	143545-90-8	FALSE	FALSE	ND	0.010	0.090	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC5	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3 July Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0342-01	Water	Water	07/05/2018 08:38:00	07/09/2018 08:12:00	07/09/2018 14:54:48	A809673	UCMR4, EPA 545	EPA 545	EPA 545	Uracil-d4	24897-55-0	FALSE	FALSE	20			ug/L	FALSE	NA	1	1000	2	150	50	JMM							19890	WA5353640	EP001	SEC5	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	AM3 July Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0342-01	Water	Water	07/05/2018 08:38:00	07/09/2018 08:12:00	07/09/2018 14:54:48	A809673	UCMR4, EPA 545	EPA 545	EPA 545	L-Phenylalanine-d5	56253-90-8	FALSE	FALSE	5.0			ug/L	FALSE	NA	1	250	2	150	50	JMM							19890	WA5353640	EP001	SEC5	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM3 July Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0342-01	Water	Water	07/05/2018 08:38:00	07/11/2018 13:32:00	07/11/2018 13:32:00	A809679	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	Total Microcystin	NA	FALSE	FALSE	ND	0.15	0.30	ug/L	FALSE	NA	1					KTN							19890	WA5353640	EP001	SEC5	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3 July Week 1	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0342-01	Water	Water	07/05/2018 08:38:00	07/11/2018 13:32:00	07/11/2018 13:32:00	A809679	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	%CV (abs.)		TRUE	FALSE	5.0			ug/L	FALSE	NA	1	1000	0.5	15	0	KTN							19890	WA5353640	EP001	SEC5	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3 July Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0343-01	Water	Water	07/20/2018 09:14:00	07/30/2018 14:00:00	07/31/2018 14:22:49	A810886	UCMR4, EPA 545	EPA 545	EPA 545	Anatoxin-a	64285-06-9	FALSE	FALSE	ND	0.0030	0.030	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC6	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3 July Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0343-01	Water	Water	07/20/2018 09:14:00	07/30/2018 14:00:00	07/31/2018 14:22:49	A810886	UCMR4, EPA 545	EPA 545	EPA 545	Cylindrospermopsin	143545-90-8	FALSE	FALSE	ND	0.010	0.090	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC6	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3 July Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0343-01	Water	Water	07/20/2018 09:14:00	07/30/2018 14:00:00	07/31/2018 14:22:49	A810886	UCMR4, EPA 545	EPA 545	EPA 545	Uracil-d4	24897-55-0	FALSE	FALSE	20			ug/L	FALSE	NA	1	1000	2	150	50	JMM							19890	WA5353640	EP001	SEC6	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	AM3 July Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0343-01	Water	Water	07/20/2018 09:14:00	07/30/2018 14:00:00	07/31/2018 14:22:49	A810886	UCMR4, EPA 545	EPA 545	EPA 545	L-Phenylalanine-d5	56253-90-8	FALSE	FALSE	5.0			ug/L	FALSE	NA	1	250	2	150	50	JMM							19890	WA5353640	EP001	SEC6	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM3 July Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0343-01	Water	Water	07/20/2018 09:14:00	07/31/2018 15:35:00	07/31/2018 15:35:00	A810557	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	Total Microcystin	NA	FALSE	FALSE	ND	0.15	0.30	ug/L	FALSE	NA	1					KTN							19890	WA5353640	EP001	SEC6	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3 July Week 3	BSK Associates Laboratory Fresno	Entry Point to Dist. System	V8F0343-01	Water	Water	07/20/2018 09:14:00	07/31/2018 15:35:00	07/31/2018 15:35:00	A810557	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	%CV (abs.)		TRUE	FALSE	2.9			ug/L	FALSE	NA	1	1000	0.3	15	0	KTN							19890	WA5353640	EP001	SEC6	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3/SE7	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0382-01	Water	Water	08/07/2018 11:46:00	08/09/2018 13:54:00	08/10/2018 23:37:32	A811537	UCMR4, EPA 545	EPA 545	EPA 545	Anatoxin-a	64285-06-9	FALSE	FALSE	ND	0.0030	0.030	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC7	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3/SE7	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0382-01	Water	Water	08/07/2018 11:46:00	08/09/2018 13:54:00	08/10/2018 23:37:32	A811537	UCMR4, EPA 545	EPA 545	EPA 545	Cylindrospermopsin	143545-90-8	FALSE	FALSE	ND	0.010	0.090	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC7	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3/SE7	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0382-01	Water	Water	08/07/2018 11:46:00	08/09/2018 13:54:00	08/10/2018 23:37:32	A811537	UCMR4, EPA 545	EPA 545	EPA 545	Uracil-d4	24897-55-0	FALSE	FALSE	20			ug/L	FALSE	NA	1	1000	2	150	50	JMM							19890	WA5353640	EP001	SEC7	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	AM3/SE7	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0382-01	Water	Water	08/07/2018 11:46:00	08/09/2018 13:54:00	08/10/2018 23:37:32	A811537	UCMR4, EPA 545	EPA 545	EPA 545	L-Phenylalanine-d5	56253-90-8	FALSE	FALSE	5.0			ug/L	FALSE	NA	1	250	2	150	50	JMM							19890	WA5353640	EP001	SEC7	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM3/SE7	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0382-01	Water	Water	08/07/2018 11:46:00	08/17/2018 14:40:00	08/17/2018 14:40:00	A811464	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	Total Microcystin	NA	FALSE	FALSE	ND	0.15	0.30	ug/L	FALSE	NA	1					KTN							19890	WA5353640	EP001	SEC7	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3/SE7	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0382-01	Water	Water	08/07/2018 11:46:00	08/17/2018 14:40:00	08/17/2018 14:40:00	A811464	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	%CV (abs.)		TRUE	FALSE	2.2			ug/L	FALSE	NA	1	1000	0.2	15	0	KTN							19890	WA5353640	EP001	SEC7	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3/SE8	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0383-01	Water	Water	08/23/2018 09:07:00	08/28/2018 14:36:00	08/29/2018 21:37:07	A812687	UCMR4, EPA 545	EPA 545	EPA 545	Anatoxin-a	64285-06-9	FALSE	FALSE	ND	0.0030	0.030	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC8	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3/SE8	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0383-01	Water	Water	08/23/2018 09:07:00	08/28/2018 14:36:00	08/29/2018 21:37:07	A812687	UCMR4, EPA 545	EPA 545	EPA 545	Cylindrospermopsin	143545-90-8	FALSE	FALSE	ND	0.010	0.090	ug/L	FALSE	NA	1					JMM							19890	WA5353640	EP001	SEC8	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM3/SE8	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0383-01	Water	Water	08/23/2018 09:07:00	08/28/2018 14:36:00	08/29/2018 21:37:07	A812687	UCMR4, EPA 545	EPA 545	EPA 545	Uracil-d4	24897-55-0	FALSE	FALSE	20			ug/L	FALSE	NA	1	1000	2	150	50	JMM							19890	WA5353640	EP001	SEC8	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	AM3/SE8	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0383-01	Water	Water	08/23/2018 09:07:00	08/28/2018 14:36:00	08/29/2018 21:37:07	A812687	UCMR4, EPA 545	EPA 545	EPA 545	L-Phenylalanine-d5	56253-90-8	FALSE	FALSE	5.0			ug/L	FALSE	NA	1	250	2	150	50	JMM							19890	WA5353640	EP001	SEC8	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM3/SE8	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0383-01	Water	Water	08/23/2018 09:07:00	09/04/2018 15:21:00	09/04/2018 15:21:00	A812508	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	Total Microcystin	NA	FALSE	FALSE	ND	0.15	0.30	ug/L	FALSE	NA	1					KTN							19890	WA5353640	EP001	SEC8	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM3/SE8	BSK Associates Laboratory Fresno	Seattle Intertie - EP001	V8G0383-01	Water	Water	08/23/2018 09:07:00	09/04/2018 15:21:00	09/04/2018 15:21:00	A812508	UCMR4, EPA 546 (ELISA)	EPA 546 (ELISA)	No Preparation	%CV (abs.)		TRUE	FALSE	0.0			ug/L	FALSE	NA	1	1000		15	0	KTN							19890	WA5353640	EP001	SEC8	EP		CC	SW			2

CLIENT	PROJECT	PROJECTNUM	LabName	SAMPLENAME	LABSAMPID	MATRIX	RPTMATRIX	SAMPDATE	PREPDATE	ANADATE	BATCH	METHODCODE	METHODNAME	PREPNAME	ANALYTE	CASNUMBER	SURROGATE	TIC	Result	DL	RL	UNITS	RPToMDL	BASIS	DILUTION	SPIKELEVEL	RECOVERY	UPPERCL	LOWERCL	ANALYST	PSOLIDS	LNOTE	ANOTE	LATITUDE	LONGITUDE	sComment	SNOTE1	SNOTE2	SNOTE3	SNOTE4	SNOTE5	SNOTE6	SNOTE7	SNOTE8	SNOTE9	SNOTE10	ANALYTEORDER
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/06/2018 06:02:00	09/11/2018 12:48:22	A813159	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Germanium	7440-56-4	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PSK							19890	WA5353640	EP001	SEA2	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/06/2018 06:02:00	09/11/2018 12:48:22	A813159	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Manganese	7439-96-5	FALSE	FALSE	24	0.13	0.40	ug/L	FALSE	NA	1					PSK							19890	WA5353640	EP001	SEA2	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/06/2018 06:02:00	09/11/2018 12:48:22	A813159	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Yttrium	7440-65-5	FALSE	FALSE	0.0			ug/L	FALSE	NA	1	20000		125	60	PSK							19890	WA5353640	EP001	SEA2	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Alpha-Hexachlorocyclohexane	319-84-6	FALSE	FALSE	ND	0.0033	0.010	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Chlorpyrifos	2921-88-2	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Dimethipin		FALSE	FALSE	ND	0.067	0.20	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			3
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Ethoprop	13194-48-4	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			4
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Oxyfluorfen		FALSE	FALSE	ND	0.017	0.050	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			5
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Profenophos		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH			MS3.0				19890	WA5353640	EP001	SEA2	EP		CC	SW			6
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Tebuconazole	107534-96-3	FALSE	FALSE	ND	0.067	0.20	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			7
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Total Permethrin (cis & trans)	52645-53-1	FALSE	FALSE	ND	0.013	0.040	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			10
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Tribufos (DEF)	78-48-8	FALSE	FALSE	ND	0.023	0.070	ug/L	FALSE	NA	1					JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			11
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	1,3-Dimethyl-2-nitrobenzene		TRUE	FALSE	0.83			ug/L	FALSE	NA	1	0.946	88	130	70	JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			800
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Triphenyl Phosphate	115-86-6	TRUE	FALSE	1.1			ug/L	FALSE	NA	1	0.946	116	130	70	JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			801
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Benzo(a)pyrene-d12	63466-71-7	TRUE	FALSE	0.95			ug/L	FALSE	NA	1	0.946	101	130	70	JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			802
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Acenaphthene-d10		FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Phenanthrene-d10	NA	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/10/2018 06:39:00	09/21/2018 18:10:00	A813353	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Chrysene-d12	1719-03-5	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							19890	WA5353640	EP001	SEA2	EP		CC	SW			902
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 07:35:00	09/07/2018 02:11:00	A813068	UCMR4, EPA 530	EPA 530	EPA 530	Butylated hydroxyanisole (BHA)	25013-16-5	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 07:35:00	09/07/2018 02:11:00	A813068	UCMR4, EPA 530	EPA 530	EPA 530	o-Toluidine	95-53-4	FALSE	FALSE	ND	0.0023	0.0070	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 07:35:00	09/07/2018 02:11:00	A813068	UCMR4, EPA 530	EPA 530	EPA 530	Quinoline		FALSE	FALSE	ND	0.0067	0.020	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			3
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 07:35:00	09/07/2018 02:11:00	A813068	UCMR4, EPA 530	EPA 530	EPA 530	o-Toluidine-d9	194423-47-7	TRUE	FALSE	4.1			ug/L	FALSE	NA	1	4.75	86	130	50	PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			800
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 07:35:00	09/07/2018 02:11:00	A813068	UCMR4, EPA 530	EPA 530	EPA 530	Quinoline-d7	34071-94-8	TRUE	FALSE	3.9			ug/L	FALSE	NA	1	4.75	82	130	70	PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			801
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 07:35:00	09/07/2018 02:11:00	A813068	UCMR4, EPA 530	EPA 530	EPA 530	Acenaphthene-d10		FALSE	FALSE	1000			ng/mL	FALSE	NA	1	25000	4	130	70	PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			900
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 07:35:00	09/07/2018 02:11:00	A813068	UCMR4, EPA 530	EPA 530	EPA 530	Phenanthrene-d10	NA	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	25000	4	130	70	PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 09:53:00	09/13/2018 06:17:00	A813076	UCMR4, EPA 541	EPA 541	EPA 541	Allyl alcohol	107-18-6	FALSE	FALSE	ND	0.17	0.50	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			1
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 09:53:00	09/13/2018 06:17:00	A813076	UCMR4, EPA 541	EPA 541	EPA 541	n-Butyl alcohol	71-36-3	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			2
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 09:53:00	09/13/2018 06:17:00	A813076	UCMR4, EPA 541	EPA 541	EPA 541	2-Methoxyethanol	109-86-4	FALSE	FALSE	ND	0.13	0.40	ug/L	FALSE	NA	1					PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			3
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 09:53:00	09/13/2018 06:17:00	A813076	UCMR4, EPA 541	EPA 541	EPA 541	n-Butyl alcohol-d10	34193-38-9	TRUE	FALSE	8.2			ug/L	FALSE	NA	1	10.0	82	130	70	PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			801
City of Mercer Island, WA	UCMR4	AM1/SE2	BSK Associates Laboratory Fresno	Seattle Intertie	V8G0384-01	Water	Water	08/29/2018 13:54:00	09/05/2018 09:53:00	09/13/2018 06:17:00	A813076	UCMR4, EPA 541	EPA 541	EPA 541	Chlorobenzene-d5	03114-55-4	FALSE	FALSE	250			ng/mL	FALSE	NA	1	25000	1	130	70	PNN							19890	WA5353640	EP001	SEA2	EP		CC	SW			901
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/07/2018 19:47:00	09/08/2018 06:10:29	A813328	UCMR4 Bromide	EPA 300.0	Method Specific Preparation	Bromide	24959-67-9	FALSE	FALSE	20	6.7	20	ug/L	FALSE	NA	1					BCB							00001	WA5353640	SSEAST	SEH1	DS						3
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.63	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						1
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	0.63	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						2
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						3
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						4
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						5
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						6
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	7.7	0.067	0.20	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						7
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						8
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	9.0	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSEAST	SEH1	DS						9
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	10			ug/L	FALSE	NA	1	10.0	100	130	70	JKH							00001	WA5353640	SSEAST	SEH1	DS						800
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 18:53:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	JKH							00001	WA5353640	SSEAST	SEH1	DS						900
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSEast	V8G0387-01	Water	Water	07/18/2018 00:00:00	09/10/2018 17:55:00	09/10/2018 17:55:00	A813398	UCMR4 TOC, Total Organic Carbon	SM 5310C	Method Specific Preparation	Total Organic Carbon		FALSE	FALSE	ND	330	1000	ug/L	FALSE	NA	1					CEG							00001	WA5353640	SSEAST	SEH1	DS						1
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/07/2018 19:47:00	09/08/2018 06:21:55	A813328	UCMR4 Bromide	EPA 300.0	Method Specific Preparation	Bromide	24959-67-9	FALSE	FALSE	ND	6.7	20	ug/L	FALSE	NA	1					BCB							00001	WA5353640	SSNORTH	SEH1	DS						3
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.61	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						1
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	0.71	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						2
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						3
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						4
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						5
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						6
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	7.4	0.067	0.20	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						7
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						8
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	9.7	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSNORTH	SEH1	DS						9
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	10			ug/L	FALSE	NA	1	10.0	100	130	70	JKH							00001	WA5353640	SSNORTH	SEH1	DS						800
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:10:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	JKH							00001	WA5353640	SSNORTH	SEH1	DS						900
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSNorth	V8G0387-02	Water	Water	07/18/2018 00:00:00	09/10/2018 18:08:00	09/10/2018 18:08:00	A813398	UCMR4 TOC, Total Organic Carbon	SM 5310C	Method Specific Preparation	Total Organic Carbon		FALSE	FALSE	ND	330	1000	ug/L	FALSE	NA	1					CEG							00001	WA5353640	SSNORTH	SEH1	DS						1
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/07/2018 19:47:00	09/08/2018 06:33:21	A813328	UCMR4 Bromide	EPA 300.0	Method Specific Preparation	Bromide	24959-67-9	FALSE	FALSE	21	6.7	20	ug/L	FALSE	NA	1					BCB							00001	WA5353640	SSSOUTH	SEH1	DS						3
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.37	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						1
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	0.70	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						2
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						3
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						4
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						5
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						6
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	3.1	0.067	0.20	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						7
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						8
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	9.8	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSSOUTH	SEH1	DS						9
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	9.9			ug/L	FALSE	NA	1	10.0	99	130	70	JKH							00001	WA5353640	SSSOUTH	SEH1	DS						800
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 20:36:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	JKH							00001	WA5353640	SSSOUTH	SEH1	DS						900
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSSouth	V8G0387-03	Water	Water	07/18/2018 00:00:00	09/10/2018 18:21:00	09/10/2018 18:21:00	A813398	UCMR4 TOC, Total Organic Carbon	SM 5310C	Method Specific Preparation	Total Organic Carbon		FALSE	FALSE	ND	330	1000	ug/L	FALSE	NA	1					CEG							00001	WA5353640	SSSOUTH	SEH1	DS						1
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/07/2018 19:47:00	09/08/2018 06:44:45	A813328	UCMR4 Bromide	EPA 300.0	Method Specific Preparation	Bromide	24959-67-9	FALSE	FALSE	22	6.7	20	ug/L	FALSE	NA	1					BCB							00001	WA5353640	SSWEST	SEH1	DS						3
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.60	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						1
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	0.66	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						2
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						3
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						4
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						5
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						6
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/14/2018 11:05:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	9.0	0.34	1.0	ug/L	FALSE	NA	5					JKH							00001	WA5353640	SSWEST	SEH1	DS						7
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						8
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	9.3	0.17	0.50	ug/L	FALSE	NA	1					JKH							00001	WA5353640	SSWEST	SEH1	DS						9
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/13/2018 21:02:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	10			ug/L	FALSE	NA	1	10.0	101	130	70	JKH							00001	WA5353640	SSWEST	SEH1	DS						800
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/12/2018 08:13:00	09/14/2018 11:05:00	A813527	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	JKH							00001	WA5353640	SSWEST	SEH1	DS						900
City of Mercer Island, WA	UCMR4	AM2/SE2	BSK Associates Laboratory Fresno	SSWest	V8G0387-04	Water	Water	07/18/2018 00:00:00	09/10/2018 18:34:00	09/10/2018 18:34:00	A813398	UCMR4 TOC, Total Organic Carbon	SM 5310C	Method Specific Preparation	Total Organic Carbon		FALSE	FALSE	ND	330	1000	ug/L	FALSE	NA	1					CEG							00001	WA5353640	SSWEST	SEH1	DS						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.33	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSEAST	SEH3	DS						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	0.68	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSEAST	SEH3	DS						2
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSEAST	SEH3	DS						3
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSEAST	SEH3	DS						4
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSEAST	SEH3	DS						5
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSEAST	SEH3	DS						6
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	4.5	0.067	0.20	ug/L	FALSE	NA	1					PNN			MS3.0				00001	WA5353640	SSEAST	SEH3	DS						7
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSEAST	SEH3	DS						8
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	15	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSEAST	SEH3	DS						9
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	9.8			ug/L	FALSE	NA	1	10.0	98	130	70	PNN							00001	WA5353640	SSEAST	SEH3	DS						800
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSEast	V8J0417-01	Water	Water	11/29/2018 11:01:00	12/04/2018 09:23:00	12/10/2018 03:32:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	PNN							00001	WA5353640	SSEAST	SEH3	DS						900
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.46	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	0.86	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						2
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						3
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						4
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						5
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						6
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	7.1	0.067	0.20	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						7
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						8
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	15	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSNORTH	SEH3	DS						9
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	10			ug/L	FALSE	NA	1	10.0	101	130	70	PNN							00001	WA5353640	SSNORTH	SEH3	DS						800
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSNorth	V8J0417-02	Water	Water	11/29/2018 12:08:00	12/04/2018 09:23:00	12/10/2018 04:51:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	PNN							00001	WA5353640	SSNORTH	SEH3	DS						900
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	0.69	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						2
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						3
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						4
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						5
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						6
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	2.8	0.067	0.20	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						7
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						8
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	15	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSSOUTH	SEH3	DS						9
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	9.8			ug/L	FALSE	NA	1	10.0	98	130	70	PNN							00001	WA5353640	SSSOUTH	SEH3	DS						800
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSSouth	V8J0417-03	Water	Water	11/29/2018 11:20:00	12/04/2018 09:23:00	12/10/2018 05:18:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	PNN							00001	WA5353640	SSSOUTH	SEH3	DS						900
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromochloroacetic Acid (BCAA)		FALSE	FALSE	0.34	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Bromodichloroacetic Acid (BDCAA)		FALSE	FALSE	0.85	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						2
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Chlorodibromoacetic acid (CDBAA)		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						3
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Tribromoacetic Acid (TBAA)		FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						4
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monobromoacetic Acid (MBAA)	79-08-3	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						5
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dibromoacetic Acid (DBAA)	631-64-1	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						6
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Dichloroacetic Acid (DCAA)	79-43-6	FALSE	FALSE	4.7	0.067	0.20	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						7
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Monochloroacetic Acid (MCAA)	79-11-8	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						8
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	Trichloroacetic Acid (TCAA)	76-03-9	FALSE	FALSE	15	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	SSWEST	SEH3	DS						9
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	2-Bromobutanoic Acid		TRUE	FALSE	9.9			ug/L	FALSE	NA	1	10.0	99	130	70	PNN							00001	WA5353640	SSWEST	SEH3	DS						800
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	SSWest	V8J0417-04	Water	Water	11/29/2018 11:38:00	12/04/2018 09:23:00	12/10/2018 05:44:00	A818055	UCMR4, EPA 552.3	EPA 552.3	EPA 552.3	1,2,3-Trichloropropane	96-18-4	FALSE	FALSE	1000			ug/L	FALSE	NA	1	1000	100	150	50	PNN							00001	WA5353640	SSWEST	SEH3	DS						900
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/10/2018 07:40:00	12/17/2018 12:02:03	A818388	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Germanium	7440-56-4	FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					PSK							00001	WA5353640	EP001	SEA3	EP						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/10/2018 07:40:00	12/17/2018 12:02:03	A818388	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Manganese	7439-96-5	FALSE	FALSE	1.6	0.13	0.40	ug/L	FALSE	NA	1					PSK							00001	WA5353640	EP001	SEA3	EP						2
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/10/2018 07:40:00	12/17/2018 12:02:03	A818388	UCMR4, EPA 200.8	EPA 200.8	UCMR4, 200.2 w/o HCl	Yttrium	7440-65-5	FALSE	FALSE	0.0			ug/L	FALSE	NA	1	20000		125	60	PSK							00001	WA5353640	EP001	SEA3	EP						901
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Alpha-Hexachlorocyclohexane	319-84-6	FALSE	FALSE	ND	0.0033	0.010	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Chlorpyrifos	2921-88-2	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						2
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Dimethipin		FALSE	FALSE	ND	0.067	0.20	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						3
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Ethoprop	13194-48-4	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						4
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Oxyfluorfen		FALSE	FALSE	ND	0.017	0.050	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						5

CLIENT	PROJECT	PROJECTNUM	LabName	SAMPLENAME	LABSAMPID	MATRIX	RPTMATRIX	SAMPDATE	PREPDATE	ANADATE	BATCH	METHODCODE	METHODNAME	PREPNAME	ANALYTE	CASNUMBER	SURROGATE	TIC	Result	DL	RL	UNITS	RPToMDL	BASIS	DILUTION	SPIKELEVEL	RECOVERY	UPPERCL	LOWERCL	ANALYST	PSOLIDS	LNOTE	ANOTE	LATITUDE	LONGITUDE	sComment	SNOTE1	SNOTE2	SNOTE3	SNOTE4	SNOTE5	SNOTE6	SNOTE7	SNOTE8	SNOTE9	SNOTE10	ANALYTEORDER
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Profenophos		FALSE	FALSE	ND	0.10	0.30	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						6
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Tebuconazole	107534-96-3	FALSE	FALSE	ND	0.067	0.20	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						7
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Total Permethrin (cis & trans)	52645-53-1	FALSE	FALSE	ND	0.013	0.040	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						10
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Tribufos (DEF)	78-48-8	FALSE	FALSE	ND	0.023	0.070	ug/L	FALSE	NA	1					JKH							00001	WA5353640	EP001	SEA3	EP						11
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	1,3-Dimethyl-2-nitrobenzene		TRUE	FALSE	0.87			ug/L	FALSE	NA	1	0.949	92	130	70	JKH							00001	WA5353640	EP001	SEA3	EP						800
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Triphenyl Phosphate	115-86-6	TRUE	FALSE	0.93			ug/L	FALSE	NA	1	0.949	98	130	70	JKH							00001	WA5353640	EP001	SEA3	EP						801
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Benzo(a)pyrene-d12	63466-71-7	TRUE	FALSE	0.90			ug/L	FALSE	NA	1	0.949	95	130	70	JKH							00001	WA5353640	EP001	SEA3	EP						802
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Acenaphthene-d10		FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							00001	WA5353640	EP001	SEA3	EP						900
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Phenanthrene-d10	NA	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							00001	WA5353640	EP001	SEA3	EP						901
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/09/2018 11:32:00	12/10/2018 22:44:00	A818376	UCMR4, EPA 525.3	EPA 525.3	EPA 525.3	Chrysene-d12	1719-03-5	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	50000	2	130	70	JKH							00001	WA5353640	EP001	SEA3	EP						902
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/05/2018 08:18:00	12/07/2018 12:40:00	A818141	UCMR4, EPA 530	EPA 530	EPA 530	Butylated hydroxyanisole (BHA)	25013-16-5	FALSE	FALSE	ND	0.010	0.030	ug/L	FALSE	NA	1					PNN							00001	WA5353640	EP001	SEA3	EP						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/05/2018 08:18:00	12/07/2018 12:40:00	A818141	UCMR4, EPA 530	EPA 530	EPA 530	o-Toluidine	95-53-4	FALSE	FALSE	ND	0.0023	0.0070	ug/L	FALSE	NA	1					PNN							00001	WA5353640	EP001	SEA3	EP						2
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/05/2018 08:18:00	12/07/2018 12:40:00	A818141	UCMR4, EPA 530	EPA 530	EPA 530	Quinoline		FALSE	FALSE	ND	0.0067	0.020	ug/L	FALSE	NA	1					PNN							00001	WA5353640	EP001	SEA3	EP						3
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/05/2018 08:18:00	12/07/2018 12:40:00	A818141	UCMR4, EPA 530	EPA 530	EPA 530	o-Toluidine-d9	194423-47-7	TRUE	FALSE	5.2			ug/L	FALSE	NA	1	4.73	109	130	50	PNN							00001	WA5353640	EP001	SEA3	EP						800
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/05/2018 08:18:00	12/07/2018 12:40:00	A818141	UCMR4, EPA 530	EPA 530	EPA 530	Quinoline-d7	34071-94-8	TRUE	FALSE	4.4			ug/L	FALSE	NA	1	4.73	92	130	70	PNN							00001	WA5353640	EP001	SEA3	EP						801
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/05/2018 08:18:00	12/07/2018 12:40:00	A818141	UCMR4, EPA 530	EPA 530	EPA 530	Acenaphthene-d10		FALSE	FALSE	1000			ng/mL	FALSE	NA	1	25000	4	130	70	PNN							00001	WA5353640	EP001	SEA3	EP						900
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/05/2018 08:18:00	12/07/2018 12:40:00	A818141	UCMR4, EPA 530	EPA 530	EPA 530	Phenanthrene-d10	NA	FALSE	FALSE	1000			ng/mL	FALSE	NA	1	25000	4	130	70	PNN							00001	WA5353640	EP001	SEA3	EP						901
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/17/2018 09:49:00	12/18/2018 22:21:00	A818761	UCMR4, EPA 541	EPA 541	EPA 541	Allyl alcohol	107-18-6	FALSE	FALSE	ND	0.17	0.50	ug/L	FALSE	NA	1					PNN							00001	WA5353640	EP001	SEA3	EP						1
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/17/2018 09:49:00	12/18/2018 22:21:00	A818761	UCMR4, EPA 541	EPA 541	EPA 541	n-Butyl alcohol	71-36-3	FALSE	FALSE	ND	0.67	2.0	ug/L	FALSE	NA	1					PNN							00001	WA5353640	EP001	SEA3	EP						2
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/17/2018 09:49:00	12/18/2018 22:21:00	A818761	UCMR4, EPA 541	EPA 541	EPA 541	2-Methoxyethanol	109-86-4	FALSE	FALSE	ND	0.13	0.40	ug/L	FALSE	NA	1					PNN							00001	WA5353640	EP001	SEA3	EP						3
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/17/2018 09:49:00	12/18/2018 22:21:00	A818761	UCMR4, EPA 541	EPA 541	EPA 541	n-Butyl alcohol-d10	34193-38-9	TRUE	FALSE	8.6			ug/L	FALSE	NA	1	10.0	86	130	70	PNN							00001	WA5353640	EP001	SEA3	EP						801
City of Mercer Island, WA	UCMR4	SE3	BSK Associates Laboratory Fresno	Seattle Intertie	V8J0424-01	Water	Water	11/29/2018 09:17:00	12/17/2018 09:49:00	12/18/2018 22:21:00	A818761	UCMR4, EPA 541	EPA 541	EPA 541	Chlorobenzene-d5	03114-55-4	FALSE	FALSE	250			ng/mL	FALSE	NA	1	25000	1	130	70	PNN							00001	WA5353640	EP001	SEA3	EP						901