

CITY OF MERCER ISLAND
9611 SE 36th Street
Mercer Island, WA 98040

SEWER SCADA SYSTEMS REPLACEMENT

BID NUMBER: 22-31

**ADDENDUM NO. 3
TO THE CONTRACT DOCUMENTS**



ISSUED THIS DATE: OCTOBER 28, 2022

BID OPENING: 2:00 PM (PST) ON THURSDAY, NOVEMBER 3, 2022

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED IN THE BID FORM

TO PROSPECTIVE BIDDERS:

The attention of all prospective bidders for the above project is directed to the following clarifications and modifications to the Contract Documents.

Clarifications to Bidder's Questions:

Ref No.	Location and Description of Change
Q-7	<p><i>Clarification to previous bidder question Q-7: Will the wet wells be active? Will they be cleaned prior to any possible entry?</i></p> <p>Answer: The wetwells will continue to be active throughout installation/construction. The wetwells historically have been entered 'as is' during normal operation. The wetwell levels are low enough such that they will not prohibit wetwell entry or interfere with the required work. For bid purposes, assume work identified in the Contract Documents associated with the wetwell, e.g., float switch demolition and FOGRod installation/adjustment, will require wetwell entry at all stations.</p>

Specifications:

Ref No.	Spec or Drawing	Location and Description of Change
3.01	Bid Form	DELETE the following line in the Bid Schedule in the Bid Form: Washington State Excise Tax (10.25%) = \$_____