



First Hill Booster Pump Station Generator Replacement
PROJECT NUMBER: 25-55

ADDENDUM NO. 2

ISSUED THIS DATE: January 22, 2026

BID OPENING: 2:00 PM (PST) on Thursday, January 29, 2026

This addendum is for the First Hill Booster Pump Station Generator Replacement project , Project No. 25-55, issued December 29, 2025. This document is issued to revise the contract documents and to provide responses to questions received during the open question period, which ended on Thursday, January 22, 2026, at 12 noon.

The addendum shall become fully a part of the above-named project drawing, specifications, and bid documents. Each bidder shall be responsible for reading this addendum to ascertain to what extent and in what manner it affects the work to be performed. All bidders must acknowledge their receipt of this addendum on the Bid Form.

This Addendum consists of a total of two (2) pages, consisting of the following:

1. ADDENDUM No. 02, dated January 22, 2026. Total of 2 pages.

Questions & Answers

Q1: Is there any lead or asbestos known at this project. Specs say it would be incidental , but I don't think that's very fair- I believe unless city has conducted a survey it should be extra work to test for it and also to abate it if it's found.


A1: There are no known lead or asbestos containing materials at the Project Site. If lead or asbestos-containing materials are encountered, such discovery shall be treated as a Differing Site Condition. The Contractor shall provide immediate written notice to the City and submit a request for a Change Order in accordance with Article 5.3 of the City's General Terms and Conditions (November 2024 edition).

Q2: Specifications 16110 2.4 call out HDG or fiberglass for racks. Does this section refer to conduit racks only? Plans Page E7 specify stainless steel for the equipment rack . Please clarify.

A2: Where there is a discrepancy between the Plan Drawings and the Specifications, the Plan Drawings shall govern. Unistrut framework for the Electrical Equipment Enclosure shall be stainless steel P1001. All other racks, not specifically called out on the Plan Drawings, shall be of the materials and construction specified on page TS-152 of the Specifications.

Additions and/or Modifications to the Contract Documents

Ref	Spec or Drawing	Location and Description of Change
A	Spec Section 02050 Demolition	Modify Pages TS-67-68 Amend items 1.5H and 1.6D to read: "All costs associated with the demolition, removal, and abandonment of asbestos-containing materials shall be paid for by the City through a Change Order."



Christopher Marks, P.E.

Utilities Engineer, City of Mercer Island