



First Hill Booster Pump Station Generator Replacement
PROJECT NUMBER: 25-55

ADDENDUM NO. 3

ISSUED THIS DATE: January 23, 2026

BID OPENING: 2:00 PM (PST) on Thursday, January 29, 2026

This addendum is for the First Hill Booster Pump Station Generator Replacement project , Project No. 25-55, issued December 29, 2025.

NOTE: A Microsoft service outage on January 22, 2026 affected Microsoft 365 services, including Outlook, which delayed delivery of Contractor questions to City inboxes.

The addendum shall become fully a part of the above-named project drawing, specifications, and bid documents. Each bidder shall be responsible for reading this addendum to ascertain to what extent and in what manner it affects the work to be performed. All bidders must acknowledge their receipt of this addendum on the Bid Form.

This Addendum consists of a total of one (1) page, consisting of the following:

1. ADDENDUM No. 03, dated January 23, 2026. Total of 1 page.


Questions & Answers

Q1: I have received inquiries on the project; however Caterpillar, CAT, is not on the acceptable manufacturer/supplier list. I am seeking approval to quote this project

A1: Caterpillar Inc. (CAT) generator sets meeting the requirements of Section 16200 of the Technical Specifications are approved for use.

Additions and/or Modifications to the Contract Documents

Ref	Spec or Drawing	Location and Description of Change
A	Spec Section 16200 Power Generation Section 2. Products	Modify Subsection 2.1 Acceptable Manufacturer/Supplier Page TS-172 ADD Caterpillar generators, CAT, to the list of acceptable Manufacturers. Amend sentence 4 to read: " Other acceptable manufacturers are Kohler or CAT. "

A handwritten signature in black ink, appearing to read "Christopher Marks".

Christopher Marks, P.E.

Utilities Engineer, City of Mercer Island